

October 6, 2021

Dear Carver High School Community,

We wanted to provide an update to the Carver High School Community (Carver Early College and Carver STEAM Academy) regarding some maintenance efforts underway in the school's gym.

As part of the Atlanta Public Schools Facilities team's review of lighting in the gym at Carver High School on September 13th, a mildew/mold substance was identified on the ceiling and upper walls in the gym. APS Facilities has scheduled a specialized cleaning vendor to clean the mildew/mold substance from the ceiling and the upper levels of the walls at the gym, starting tomorrow, October 7th and continue over the extended weekend (through Monday, October 11th). This cleaning work includes the cleaning of the air ducts, ceiling and wall surfaces, coils in the HVAC system, and air handling rooms.

Our team has inspected this issue and concludes that this mold/mildew is not from a roof leak or HVAC condensation leak but is from long periods of high humidity in the upper levels of the gymnasium. APS Facilities will review the root cause of the elevated humidity levels after the immediate clean-up is completed. The gym remains safe to occupy during this period of time.

Thank you for your patience as we work through this maintenance. If you have any questions, please feel free to contact Rudy Parsons in our facilities department at rparsons@atlanta.k12.ga.us.

Sincerely,

Mr. Tommy Usher,
K-12 Associate Superintendent
Carver and South Atlanta Cluster Schools

Mr. Matt Underwood
Executive Director
Office of Charter and Partner Schools

6 de octubre de 2021

Estimada comunidad de Carver High School,

Queríamos proporcionar una actualización a la comunidad de la escuela secundaria Carver (Carver Early College y Carver STEAM Academy) con respecto a algunos esfuerzos de mantenimiento en curso en el gimnasio de la escuela.

Como parte de la revisión del equipo de Instalaciones de las Escuelas Públicas de Atlanta de la iluminación en el gimnasio de Carver High School el 13 de septiembre, se identificó una sustancia de moho en el techo y las paredes superiores del gimnasio. Instalaciones de APS ha programado un proveedor de limpieza especializado para limpiar el moho / sustancia de moho del techo y los niveles superiores de las paredes en el gimnasio, a partir de mañana, 7 de octubre y continuar durante el fin de semana extendido (hasta el lunes 11 de octubre). Este trabajo de limpieza incluye la limpieza de los conductos de aire, las superficies del techo y las paredes, los serpentines del sistema HVAC y las salas de tratamiento de aire.

Nuestro equipo ha inspeccionado este problema y concluye que este moho no se debe a una fuga en el techo ni a una fuga de condensación de HVAC, sino a períodos prolongados de alta humedad en los niveles superiores del gimnasio. Las instalaciones de APS revisarán la causa raíz de los niveles elevados de humedad después de que se complete la limpieza inmediata. El gimnasio sigue siendo seguro para ocupar durante este período de tiempo.

Gracias por su paciencia mientras trabajamos en este mantenimiento. Si tiene alguna pregunta, no dude en ponerse en contacto con Rudy Parsons en nuestro departamento de instalaciones en rparsons@atlanta.k12.ga.us.

Atentamente,

Mr. Tommy Usher,
K-12 Associate Superintendent
Carver and South Atlanta Cluster Schools

Mr. Matt Underwood
Executive Director
Office of Charter and Partner Schools