

Atlanta Public Schools/ S. Atlanta Cluster

Cleveland Avenue Elementary School

Revised

School Assessment Report

November 10, 2020



Table of Contents

School Executive Summary	4
School Dashboard Summary	7
School Condition Summary	8
<u>1996 Bldg 2010</u>	10
Executive Summary	10
Dashboard Summary	11
Condition Summary	12
Photo Album	13
Condition Detail	14
System Listing	15
System Notes	18
Renewal Schedule	27
Forecasted Sustainment Requirement	30
Condition Index Forecast by Investment Scenario	31
Deficiency Summary By System	32
Deficiency Summary By Priority	33
Deficiency By Priority Investment	34
Deficiency Summary By Category	35
Deficiency Details By Priority	36
<u>Site</u>	38
Executive Summary	38
Dashboard Summary	39
Condition Summary	40
Photo Album	41
Condition Detail	42
System Listing	43
System Notes	44
Renewal Schedule	49
Forecasted Sustainment Requirement	50

School Assessment Report

Condition Index Forecast by Investment Scenario	51
Deficiency Summary By System	52
Deficiency Summary By Priority	53
Deficiency By Priority Investment	54
Deficiency Summary By Category	55
Deficiency Details By Priority	56
Glossary	57

School Executive Summary

The condition of a Campus is the accumulation of the condition evaluations of the component buildings and the site. Building condition is evaluated based on the functional systems and elements of a building and organized according to the **UNIFORMAT II Elemental Classification**. eCOMET uses parametric estimating methodology whereby historical costs for systems, components and equipment are collected by entities such as RSMeans and converted to unit costs, typically \$/SF, and used to approximate future construction costs or replacement values. The grouping of these systems and elements and applying a current replacement value to them develops a representative building cost model. Cost Models are developed for similar building types and functions. Systems and their elements are evaluated based on their current replacement values, life cycles, installation dates and next renewal dates. Systems and their elements that are within their useful lives are further evaluated to identify current deficient conditions that may have a significant impact on a system's or element's remaining service life, and to determine if they are beyond their predicted expected life. The system's or element's current replacement value is based on RS Means Commercial Cost Data.

Following are the cost model's system details for this facility. The **Current Replacement Value (CRV)** is the amount needed to replace the property of the same present scope. The **Repair Cost** (the sum of the cost to repair/replace the Deficiencies) represents the budgeted contractor-installed costs plus owner's soft costs for the repair, replacement or renewal for a component or system level deficiency. It excludes contributing costs for other components or systems that might also be associated with the corrective actions due to packaging of the work. **Facility Condition Index (FCI)** is an industry-standard measurement of facility condition calculated as the ratio of the costs to correct a facility's deficiencies (Condition Needs) to the facility's Current Replacement Value. It ranges from 0% (new) to 100% (very poor - beyond service life). The **Remaining Service Life Index (RSLI)** is calculated as the sum of a renewable system's **Remaining Service Life (RSL)** divided by the sum of a system's Replacement Value (both values exclude soft-cost to simplify calculation updates) expressed as a percentage ranging from 100% (new) to 0% (expired). The relationship between the key metrics FCI and RSLI is an important indicator, at either the facility, building, system, or component levels, of the condition trend and the imminent need for capital renewal. These indices exist in an inverse relationship wherein the FCI increases when systems reach their expected life-cycle age, whereas the RSLI decreases annually indicating the relative time remaining before reaching the life-cycle expiration age. For example, a facility or a system with a high RSLI and a low FCI indicates it is in the early portion of its useful life. However, a low RSLI indicates that expiration dates are approaching at which point the FCI would increase. The term **FCA Score** is the inverse of Total FCI and calculated as $100 - \text{Total FCI}$ (without the %) where 100 is best and 0 is worst condition.

Gross Area (SF):	75,286
Year Built:	1996
Last Renovation:	
Replacement Value:	\$15,477,118
Repair Cost:	\$883,476.00
Total FCI:	5.71 %
Total RSLI:	41.67 %
FCA Score:	94.29



Description:

Cleveland Avenue Elementary School is located 2672 Old Hapeville Road in Atlanta, Georgia. The single story, 75,286 square foot building was originally constructed in 1996.

This report contains condition and adequacy data collected during the 2019 Facility Condition Assessment (FCA) Update. Detailed condition and deficiency statements are contained in this report for the site and building elements.

SUBSTRUCTURE

The building rests on slab-on grade and is assumed to have standard cast-in-place concrete foundations. The building does not have a basement.

SUPERSTRUCTURE

Floor construction is metal pan deck with lightweight fill. Roof construction is metal pan deck with lightweight fill. The exterior envelope is composed of walls of brick veneer over CMU. Exterior windows are aluminum frame with operable panes. Exterior doors are hollow metal steel mostly with glazing. Roofing is typically Preformed Metal Roofing. Most building entrances appear to comply

School Assessment Report - Cleveland Avenue Elementary School

with ADA requirements.

INTERIORS

Interior partitions are typically CMU. Interior doors are generally solid core wood with hollow metal frames and mostly with glazing. Interior fittings include the following items: white boards, graphics and identifying devices, toilet accessories, storage shelving, handrails, fabricated toilet partitions. The interior wall finishes are typically painted CMU. Floor finishes in common areas are typically vinyl composition tile. Floor finishes in assignable spaces is typically vinyl composition tile, carpet, and ceramic tile. Ceiling finishes in common areas are typically suspended acoustical tile. Ceiling finishes in assignable areas are typically suspended acoustical tile.

SERVICES

CONVEYING: The building does not include conveying equipment. Conveying equipment includes no hydraulic elevators, and no wheelchair lifts.

PLUMBING:

Plumbing fixtures are typically low-flow water fixtures with manual control valves. Domestic water distribution is combination of copper and galvanized steel with electric hot water heating. Sanitary waste system is cast iron. Rainwater drainage system is internal with roof drains.

HVAC:

Heating is provided by gas fired boilers. Cooling is supplied by pad and/or wall mounted package units. The heating/cooling distribution system is a ductwork system utilizing air handling units. Ceiling mounted exhaust fans are installed in bathrooms and other required areas. Controls and instrumentation are digital and are centrally controlled by an energy management system. This building has a remote Building Automation System.

FIRE PROTECTION:

The building does have a fire sprinkler system. The building does have a kitchen hood fire suppression system. Fire extinguishers and cabinets are distributed near fire exits and corridors.

ELECTRICAL:

The main electrical service is fed from a pad mounted transformer to the main switchboard/distribution panel located in the building. Lighting is lay-in type, fluorescent light fixtures. Branch circuit wiring is typically copper serving electrical switches and receptacles. Emergency and life safety egress lighting systems are installed and exit signs are present at exit doors and near stairways and are typically illuminated.

COMMUNICATIONS AND SECURITY:

The fire alarm system consists of audible/visual strobe annunciators in all common spaces. The system is activated by manual pull stations and smoke detectors and the system is centrally monitored. The telephone and data systems are segregated and include dedicated equipment closets. This building does have a local area network (LAN). The building includes an internal security system that is actuated by the following items: contacts, infrared, optical or a combination of all devices. The building has controlled entry doors access provided by card readers; entry doors are secured with magnetic door locks. The security system has CCTV cameras and is centrally monitored; this building has a public address and paging system combined with the telephone system.

OTHER ELECTRICAL SYSTEMS:

This building does not have a separately derived emergency power system. There is no natural gas emergency generator.

EQUIPMENT & FURNISHINGS

This building includes the following items and equipment: fixed food service, library equipment, fixed casework, window treatment, floor grilles and mats, and multiple seating furnishings.

SITE

Campus site features include paved driveways and parking lots, pedestrian pavement, flagpole, covered walkway, landscaping, track and fencing. Site mechanical and electrical features include water, sewer, natural gas and site lighting.

CODE REVIEW

ACCESSIBILITY: The building is generally in compliance with applicable ADA requirements with respect to path of travel, interior and exterior doors, interior signage, and toilet room dimensions, fixtures, and fittings. Most building entrances appear to comply with ADA requirements.

LIFE-SAFETY SYSTEMS: The building is not covered with a wet sprinkler system. Fire extinguishers are located throughout the building. Power outlets in wet areas are GFIC protected. The fire alarm system includes detection devices, audio/visual alarms, and

School Assessment Report - Cleveland Avenue Elementary School

pull stations. Emergency/egress lighting is a combination of battery and special circuit systems. Illuminated exit signage is present in corridors and at exit doors. There is no fall protection at the roof.

Attributes:

General Attributes:


Arch Condition Assessor:	Jejuan Hall	MEP Condition Assessor:	Homero Guerrero
School Grades:	01, 02, 03, 04, 05, KK, PK	DOE Drawing Total GSF:	75880
DOE Facility Number:	4056	Total # of Modular/Portables:	0
DOE Interior Site SF:	75286	Total GSF of Modular/Portables:	0
Approx. Acres:	4.8	Status:	Active

School Dashboard Summary


Gross Area: 75,286
 Year Built: 1996
 Repair Cost: \$883,476
 FCI: 5.71 %

Last Renovation:
 Replacement Value: \$15,477,118
 RSLI%: 41.67 %


Deficiency By Category




Deficiency By Priority



Deficiency By System



10 Year Investment Forecast



School Condition Summary

The Table below shows the RSLI and FCI for each major system shown at the UNIFORMAT II classification Level 2. Note that Systems with lower FCIs require less investment than systems with higher FCIs.


Current Investment Requirement and Condition by Unifomat Classification

UNIFORMAT Classification	RSLI%	FCI %	Current Repair
A10 - Foundations	77.00 %	0.00 %	\$0.00
B10 - Superstructure	77.00 %	0.00 %	\$0.00
B20 - Exterior Enclosure	55.17 %	0.00 %	\$0.00
B30 - Roofing	23.33 %	0.00 %	\$0.00
C10 - Interior Construction	49.14 %	24.74 %	\$246,788.00
C30 - Interior Finishes	29.86 %	3.40 %	\$41,250.00
D20 - Plumbing	28.17 %	0.00 %	\$0.00
D30 - HVAC	29.09 %	0.00 %	\$0.00
D40 - Fire Protection	25.97 %	0.00 %	\$0.00
D50 - Electrical	33.09 %	13.46 %	\$242,647.00
E10 - Equipment	30.00 %	0.00 %	\$0.00
E20 - Furnishings	30.00 %	0.00 %	\$0.00
G20 - Site Improvements	29.48 %	0.00 %	\$0.00
G30 - Site Mechanical Utilities	54.00 %	0.00 %	\$0.00
G40 - Site Electrical Utilities	8.74 %	68.81 %	\$352,791.00
Totals:	41.67 %	5.71 %	\$883,476.00

Condition Deficiency Priority

Facility Name	Gross Area (S.F.)	FCI %	1 - Critical Immediate Need	2 - Trending Critical (Year 1)	3 - Necessary (Years 2-5)	4 - Recommended (Years 6-10)	5 - Grandfathered Project triggered
1996 Bldg 2010	75,286	4.06	\$0.00	\$0.00	\$499,215.00	\$31,470.00	\$0.00
Site	75,286	14.60	\$0.00	\$0.00	\$352,791.00	\$0.00	\$0.00
Total:		5.71	\$0.00	\$0.00	\$852,006.00	\$31,470.00	\$0.00

Deficiencies By Priority



Executive Summary

The condition of a Campus is the accumulation of the condition evaluations of the component buildings and the site. Building condition is evaluated based on the functional systems and elements of a building and organized according to the **UNIFORMAT II Elemental Classification**. eCOMET uses parametric estimating methodology whereby historical costs for systems, components and equipment are collected by entities such as RSMeans and converted to unit costs, typically \$/SF, and used to approximate future construction costs or replacement values. The grouping of these systems and elements and applying a current replacement value to them develops a representative building cost model. Cost Models are developed for similar building types and functions. Systems and their elements are evaluated based on their current replacement values, life cycles, installation dates and next renewal dates. Systems and their elements that are within their useful lives are further evaluated to identify current deficient conditions that may have a significant impact on a system's or element's remaining service life, and to determine if they are beyond their predicted expected life. The system's or element's current replacement value is based on RS Means Commercial Cost Data.

Following are the cost model's system details for this facility. The **Current Replacement Value (CRV)** is the amount needed to replace the property of the same present scope. The **Repair Cost** (the sum of the cost to repair/replace the Deficiencies) represents the budgeted contractor-installed costs plus owner's soft costs for the repair, replacement or renewal for a component or system level deficiency. It excludes contributing costs for other components or systems that might also be associated with the corrective actions due to packaging of the work. **Facility Condition Index (FCI)** is an industry-standard measurement of facility condition calculated as the ratio of the costs to correct a facility's deficiencies (Condition Needs) to the facility's Current Replacement Value. It ranges from 0% (new) to 100% (very poor - beyond service life). The **Remaining Service Life Index (RSLI)** is calculated as the sum of a renewable system's **Remaining Service Life (RSL)** divided by the sum of a system's Replacement Value (both values exclude soft-cost to simplify calculation updates) expressed as a percentage ranging from 100% (new) to 0% (expired). The relationship between the key metrics FCI and RSLI is an important indicator, at either the facility, building, system, or component levels, of the condition trend and the imminent need for capital renewal. These indices exist in an inverse relationship wherein the FCI increases when systems reach their expected life-cycle age, whereas the RSLI decreases annually indicating the relative time remaining before reaching the life-cycle expiration age. For example, a facility or a system with a high RSLI and a low FCI indicates it is in the early portion of its useful life. However, a low RSLI indicates that expiration dates are approaching at which point the FCI would increase. The term **FCA Score** is the inverse of Total FCI and calculated as $100 - \text{Total FCI}$ (without the %) where 100 is best and 0 is worst condition.

Function:	Elementary
Gross Area (SF):	75,286
Year Built:	1996
Last Renovation:	
Replacement Value:	\$13,060,438
Repair Cost:	\$530,685.00
Total FCI:	4.06 %
Total RSLI:	44.10 %
FCA Score:	95.94



Description:


The narrative for this building is included in the Executive Summary Description at the front of this report.

Attributes: This asset has no attributes.


Dashboard Summary

Function:	Elementary	Gross Area:	75,286
Year Built:	1996	Last Renovation:	
Repair Cost:	\$530,685	Replacement Value:	\$13,060,438
FCI:	4.06 %	RSLI%:	44.10 %


Deficiency By Category




Deficiency By Priority



Deficiency By System



10 Year Investment Forecast



Condition Summary

The Table below shows the RSLI and FCI for each major building system shown at the UNIFORMAT II classification Level 2. Note that Systems with lower FCIs require less investment than systems with higher FCIs.

UNIFORMAT Classification	RSLI %	FCI %	Current Repair Cost
A10 - Foundations	77.00 %	0.00 %	\$0.00
B10 - Superstructure	77.00 %	0.00 %	\$0.00
B20 - Exterior Enclosure	55.17 %	0.00 %	\$0.00
B30 - Roofing	23.33 %	0.00 %	\$0.00
C10 - Interior Construction	49.14 %	24.74 %	\$246,788.00
C30 - Interior Finishes	29.86 %	3.40 %	\$41,250.00
D20 - Plumbing	28.17 %	0.00 %	\$0.00
D30 - HVAC	29.09 %	0.00 %	\$0.00
D40 - Fire Protection	25.97 %	0.00 %	\$0.00
D50 - Electrical	33.09 %	13.46 %	\$242,647.00
E10 - Equipment	30.00 %	0.00 %	\$0.00
E20 - Furnishings	30.00 %	0.00 %	\$0.00
Totals:	44.10 %	4.06 %	\$530,685.00

Photo Album

The photo album consists of the various cardinal compass directions of the building..



Condition Detail

This section of the report contains results of the Facility Condition Assessment. The building is separated into system components based on UNIFORMAT II. The columns in the System Listing table represent the following:

1. System Code: A code that identifies the system.
2. System Description: A brief description of a system present in the building.
3. Unit Price \$: The unit price of the system.
4. UoM: The unit of measure of the system.
5. Qty: The quantity for the system
6. Life: Building Owners and Managers Association (BOMA) recommended system design life.
7. Year Installed: The date of system installation.
8. Calc Next Renewal Year: The date of system expiration based on the life, NR stands for non renewable.
9. Next Renewal Year: The suggested system expiration date by the assessor based on visual inspection.
10. RSLI: The Remaining Service Life Index of the system.
11. FCI: The Facility Condition Index of the system.
12. RSL: Remaining Service Life in years.
13. eCR: eCOMET Condition Rating (not used in this assessment)
14. Deficiency \$: The financial investment to repair/replace system to address deficiency.
15. Replacement Value \$: The replacement cost of the system as new construction.

System Listing

The System Listing table below lists each of the systems organized by their UNIFORMAT II classification. The assessment team was tasked with recording the most recent replacement year of each system, determining the remaining service life based on the theoretical life, and evaluating the condition to confirm the forecast next replacement year. The system listing is the basis for all data contained in the Building Assessment Report.

School Assessment Report - 1996 Bldg 2010

System Code	System Description	Unit Price \$	UoM	Qty	Life	Year Installed	Calc Next Renewal Year	Next Renewal Year	RSLI%	FCI%	RSL	eCR	Deficiency \$	Replacement Value \$
A1010	Standard Foundations	\$8.19	S.F.	75,286	100	1996	2096		77.00 %	0.00 %	77			\$616,592
A1020	Special Foundations	\$0.39	S.F.	75,286	100	1996	2096		77.00 %	0.00 %	77			\$29,362
A1030	Slab on Grade	\$6.92	S.F.	75,286	100	1996	2096		77.00 %	0.00 %	77			\$520,979
B1010	Floor Construction	\$5.06	S.F.	75,286	100	1996	2096		77.00 %	0.00 %	77			\$380,947
B1020	Roof Construction	\$13.46	S.F.	75,286	100	1996	2096		77.00 %	0.00 %	77			\$1,013,350
B2010	Exterior Walls	\$15.36	S.F.	75,286	100	1996	2096		77.00 %	0.00 %	77			\$1,156,393
B2020	Exterior Windows	\$9.57	S.F.	75,286	30	1996	2026		23.33 %	0.00 %	7			\$720,487
B2030	Exterior Doors	\$0.96	S.F.	75,286	30	1996	2026		23.33 %	0.00 %	7			\$72,275
B3010130	Preformed Metal Roofing	\$8.50	S.F.	75,286	30	1996	2026		23.33 %	0.00 %	7			\$639,931
B3020	Roof Openings	\$0.57	S.F.	75,286	30	1996	2026		23.33 %	0.00 %	7			\$42,913
C1010	Partitions	\$6.22	S.F.	75,286	100	1996	2096		77.00 %	0.00 %	77			\$468,279
C1020	Interior Doors	\$4.05	S.F.	75,286	40	1996	2036		42.50 %	0.00 %	17			\$304,908
C1030	Fittings	\$2.98	S.F.	75,286	20	1996	2016		0.00 %	110.00 %	-3		\$246,788.00	\$224,352
C3010230	Paint & Covering	\$1.47	S.F.	75,286	10	1996	2006		0.00 %	0.00 %	-13			\$110,670
C3020420	Ceramic Tile	\$16.74	S.F.	5,000	50	1996	2046		54.00 %	0.00 %	27			\$83,700
C3020901	Carpet	\$7.50	S.F.	5,000	8	1996	2004		0.00 %	110.00 %	-15		\$41,250.00	\$37,500
C3020903	VCT	\$3.48	S.F.	65,286	15	1996	2011	2025	40.00 %	0.00 %	6			\$227,195
C3030	Ceiling Finishes	\$10.00	S.F.	75,286	20	1996	2016	2025	30.00 %	0.00 %	6			\$752,860
D2010	Plumbing Fixtures	\$7.06	S.F.	75,286	20	1996	2016	2025	30.00 %	0.00 %	6			\$531,519
D2020	Domestic Water Distribution	\$0.79	S.F.	75,286	30	1996	2026		23.33 %	0.00 %	7			\$59,476
D2030	Sanitary Waste	\$1.89	S.F.	75,286	30	1996	2026		23.33 %	0.00 %	7			\$142,291
D3010	Energy Supply	\$0.61	S.F.	75,286	30	1996	2026		23.33 %	0.00 %	7			\$45,924
D3020	Heat Generating Systems	\$4.00	S.F.	75,286	20	2013	2033		70.00 %	0.00 %	14			\$301,144
D3030	Cooling Generating Systems	\$6.78	S.F.	75,286	20	2015	2035		80.00 %	0.00 %	16			\$510,439
D3040	Distribution Systems	\$11.81	S.F.	75,286	20	1996	2016	2020	5.00 %	0.00 %	1			\$889,128
D3050	Terminal & Package Units	\$7.39	S.F.	75,286	15	1996	2011	2020	6.67 %	0.00 %	1			\$556,364
D3060	Controls & Instrumentation	\$2.46	S.F.	75,286	15	1996	2011	2020	6.67 %	0.00 %	1			\$185,204
D4010	Sprinklers	\$4.54	S.F.	75,286	30	1996	2026		23.33 %	0.00 %	7			\$341,798
D4030	Fire Protection Specialties	\$0.10	S.F.	75,286	15	2012	2027		53.33 %	0.00 %	8			\$7,529
D4090	Other Fire Protection Systems	\$0.66	S.F.	75,286	15	2004	2019	2025	40.00 %	0.00 %	6			\$49,689
D5010	Electrical Service/Distribution	\$2.55	S.F.	75,286	20	1996	2016	2025	30.00 %	110.00 %	6		\$211,177.00	\$191,979
D5020	Branch Wiring	\$5.28	S.F.	75,286	20	1996	2016	2025	30.00 %	0.00 %	6			\$397,510
D5020	Lighting	\$7.92	S.F.	75,286	20	1996	2016	2025	30.00 %	0.00 %	6			\$596,265
D5030810	Security & Detection Systems	\$1.51	S.F.	75,286	20	2006	2026		35.00 %	0.00 %	7			\$113,682
D5030910	Fire Alarm Systems	\$2.74	S.F.	75,286	20	2006	2026		35.00 %	0.00 %	7			\$206,284
D5030920	Data Communication	\$3.56	S.F.	75,286	25	2006	2031		48.00 %	0.00 %	12			\$268,018
D5090	Other Electrical Systems	\$0.38	S.F.	75,286	15			2019	0.00 %	110.00 %	0		\$31,470.00	\$28,609
E1020	Institutional Equipment	\$0.10	S.F.	75,286	20	1996	2016	2025	30.00 %	0.00 %	6			\$7,529
E1090	Other Equipment	\$0.87	S.F.	75,286	20	1996	2016	2025	30.00 %	0.00 %	6			\$65,499
E2010	Fixed Furnishings	\$2.15	S.F.	75,286	20	1996	2016	2025	30.00 %	0.00 %	6			\$161,865
Total									44.10 %	4.06 %			\$530,685.00	\$13,060,438

System Notes

The facility description in the executive summary contains an overview of each system. The system notes listed below provide additional information on select systems found within the facility.

System: B3010130 - Preformed Metal Roofing



Note:

System: C1010 - Partitions



Note:

System: C1020 - Interior Doors



Note:



School Assessment Report - 1996 Bldg 2010

System: C1030 - Fittings



Note:

System: C3010230 - Paint & Covering



Note:

System: C3020420 - Ceramic Tile



Note:

School Assessment Report - 1996 Bldg 2010

System: C3020901 - Carpet



Note:

System: C3020903 - VCT



Note:

System: C3030 - Ceiling Finishes



Note:

School Assessment Report - 1996 Bldg 2010

System: D2010 - Plumbing Fixtures



Note:

System: D2020 - Domestic Water Distribution



Note:

System: D2030 - Sanitary Waste



Note:

School Assessment Report - 1996 Bldg 2010

System: D3020 - Heat Generating Systems



Note:

System: D3040 - Distribution Systems



Note:

System: D3060 - Controls & Instrumentation



Note:

School Assessment Report - 1996 Bldg 2010

System: D4030 - Fire Protection Specialties




Note:

System: D4090 - Other Fire Protection Systems



Note:

System: D5010 - Electrical Service/Distribution



Note:


School Assessment Report - 1996 Bldg 2010

System: D5020 - Branch Wiring




Note:

System: D5020 - Lighting



Note:

System: D5030810 - Security & Detection Systems



Note:

School Assessment Report - 1996 Bldg 2010

System: D5030910 - Fire Alarm Systems



Note:

System: D5030920 - Data Communication



Note:

System: E1020 - Institutional Equipment



Note:

School Assessment Report - 1996 Bldg 2010

System: E1090 - Other Equipment



Note:

System: E2010 - Fixed Furnishings



Note:

Renewal Schedule

eCOMET forecasts future Capital Renewal projects for expiring systems based on the Calculated Next Renewal year found in the System Listing table. There is a 3% yearly inflation factor applied to the system costs expiring in the future. The table below reflects Capital Renewal projects over the next 10 years. Note: Blank cells (or \$0) indicate no systems are scheduled for renewal in that year.

Inflation Rate: 3%

System	Current Deficiencies	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	Total
Total:	\$530,685	\$1,847,577	\$0	\$0	\$0	\$0	\$4,038,690	\$3,486,378	\$62,744	\$0	\$163,604	\$10,129,678
* A - Substructure	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
* A10 - Foundations	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
* A1010 - Standard Foundations	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
* A1020 - Special Foundations	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
* A1030 - Slab on Grade	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
B - Shell	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
B10 - Superstructure	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
* B1010 - Floor Construction	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
* B1020 - Roof Construction	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
B20 - Exterior Enclosure	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
* B2010 - Exterior Walls	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
B2020 - Exterior Windows	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$974,719	\$0	\$0	\$0	\$974,719
B2030 - Exterior Doors	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$97,777	\$0	\$0	\$0	\$97,777
B30 - Roofing	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
B3010 - Roof Coverings	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
B3010130 - Preformed Metal Roofing	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$1,125,459	\$0	\$0	\$0	\$1,125,459
B3020 - Roof Openings	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$58,055	\$0	\$0	\$0	\$58,055
C - Interiors	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
C10 - Interior Construction	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
C1010 - Partitions	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
C1020 - Interior Doors	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
C1030 - Fittings	\$246,788	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$246,788
C30 - Interior Finishes	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
C3010 - Wall Finishes	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
C3010230 - Paint & Covering	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$163,604	\$163,604

School Assessment Report - 1996 Bldg 2010

System	Current Deficiencies	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	Total
C3020 - Floor Finishes	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
C3020420 - Ceramic Tile	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
C3020901 - Carpet	\$41,250	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$52,254	\$0	\$0	\$93,504
C3020903 - VCT	\$0	\$0	\$0	\$0	\$0	\$0	\$420,489	\$0	\$0	\$0	\$0	\$420,489
C3030 - Ceiling Finishes	\$0	\$0	\$0	\$0	\$0	\$0	\$988,850	\$0	\$0	\$0	\$0	\$988,850
D - Services	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
D20 - Plumbing	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
D2010 - Plumbing Fixtures	\$0	\$0	\$0	\$0	\$0	\$0	\$698,128	\$0	\$0	\$0	\$0	\$698,128
D2020 - Domestic Water Distribution	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$80,463	\$0	\$0	\$0	\$80,463
D2030 - Sanitary Waste	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$192,500	\$0	\$0	\$0	\$192,500
D30 - HVAC	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
D3010 - Energy Supply	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$62,130	\$0	\$0	\$0	\$62,130
D3020 - Heat Generating Systems	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
D3030 - Cooling Generating Systems	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
D3040 - Distribution Systems	\$0	\$1,007,381	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$1,007,381
D3050 - Terminal & Package Units	\$0	\$630,360	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$630,360
D3060 - Controls & Instrumentation	\$0	\$209,836	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$209,836
D40 - Fire Protection	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
D4010 - Sprinklers	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$462,406	\$0	\$0	\$0	\$462,406
D4030 - Fire Protection Specialties	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$10,490	\$0	\$0	\$10,490
D4090 - Other Fire Protection Systems	\$0	\$0	\$0	\$0	\$0	\$0	\$65,265	\$0	\$0	\$0	\$0	\$65,265
D50 - Electrical	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
D5010 - Electrical Service/Distribution	\$211,177	\$0	\$0	\$0	\$0	\$0	\$252,156	\$0	\$0	\$0	\$0	\$463,333
D5020 - Branch Wiring	\$0	\$0	\$0	\$0	\$0	\$0	\$522,113	\$0	\$0	\$0	\$0	\$522,113
D5020 - Lighting	\$0	\$0	\$0	\$0	\$0	\$0	\$783,169	\$0	\$0	\$0	\$0	\$783,169
D5030 - Communications and Security	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
D5030810 - Security & Detection Systems	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$153,796	\$0	\$0	\$0	\$153,796
D5030910 - Fire Alarm Systems	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$279,073	\$0	\$0	\$0	\$279,073
D5030920 - Data Communication	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
D5090 - Other Electrical Systems	\$31,470	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$31,470
E - Equipment & Furnishings	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
E10 - Equipment	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0


School Assessment Report - 1996 Bldg 2010

System	Current Deficiencies	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	Total
E1020 - Institutional Equipment	\$0	\$0	\$0	\$0	\$0	\$0	\$9,888	\$0	\$0	\$0	\$0	\$9,888
E1090 - Other Equipment	\$0	\$0	\$0	\$0	\$0	\$0	\$86,030	\$0	\$0	\$0	\$0	\$86,030
E20 - Furnishings	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
E2010 - Fixed Furnishings	\$0	\$0	\$0	\$0	\$0	\$0	\$212,602	\$0	\$0	\$0	\$0	\$212,602

* Indicates non-renewable system

Forecasted Capital Renewal Requirement

The following chart shows the current building deficiencies and forecasted capital renewal (sustainment) requirements over the next ten years.




Condition Index Forecast by Investment Scenario

The chart below illustrates the effect of various investment levels on the building FCI for the next 10 years. The levels of investment shown below include:

- Current FCI: a variable investment amount based on renewing expired systems to maintain the current FCI for the building
- 2% Investment: an annual investment of 2% of the replacement value of the building, escalated for inflation
- 4% Investment: an annual investment of 4% of the replacement value of the building, escalated for inflation


Facility Investment vs. FCI Forecast



Year	Investment Amount Current FCI - 4.06%	2% Investment		4% Investment	
		Amount	FCI	Amount	FCI
2020	\$1,847,577	\$269,045.00	15.80 %	\$538,090.00	13.80 %
2021	\$0	\$277,116.00	13.80 %	\$554,233.00	9.80 %
2022	\$0	\$285,430.00	11.80 %	\$570,860.00	5.80 %
2023	\$0	\$293,993.00	9.80 %	\$587,986.00	1.80 %
2024	\$0	\$302,813.00	7.80 %	\$605,625.00	-2.20 %
2025	\$4,038,690	\$311,897.00	31.70 %	\$623,794.00	19.70 %
2026	\$3,486,378	\$321,254.00	51.40 %	\$642,508.00	37.40 %
2027	\$62,744	\$330,891.00	49.78 %	\$661,783.00	33.78 %
2028	\$0	\$340,818.00	47.78 %	\$681,636.00	29.78 %
2029	\$163,604	\$351,043.00	46.71 %	\$702,085.00	26.71 %
Total:	\$9,598,993	\$3,084,300.00		\$6,168,600.00	

Deficiency Summary by System


Current deficiencies included assemblies that have reached or exceeded their design life or components of the assemblies that are in need of repair. Assemblies that have reached their design life are identified as current deficiencies and assigned the distress 'Beyond Useful Life'. The following chart lists all current deficiencies associated with this facility.



Budget Estimate Total: \$530,685.00

Deficiency Summary by Priority

The following chart shows the total repair costs broken down by priority. Assessors assigned deficiencies within eCOMET to one of the following priority categories:



Budget Estimate Total: \$530,685.00


Deficiency By Priority Investment Table

The table below shows the current investment cost grouped by deficiency priority and building system.

System Code	System Description	1 - Critical Immediate Need	2 - Trending Critical (Year 1)	3 - Necessary (Years 2-5)	4 - Recommended (Years 6-10)	5 - Grandfathered Project triggered	Total
C1030	Fittings	\$0.00	\$0.00	\$246,788.00	\$0.00	\$0.00	\$246,788.00
C3020901	Carpet	\$0.00	\$0.00	\$41,250.00	\$0.00	\$0.00	\$41,250.00
D5010	Electrical Service/Distribution	\$0.00	\$0.00	\$211,177.00	\$0.00	\$0.00	\$211,177.00
D5090	Other Electrical Systems	\$0.00	\$0.00	\$0.00	\$31,470.00	\$0.00	\$31,470.00
Total:		\$0.00	\$0.00	\$499,215.00	\$31,470.00	\$0.00	\$530,685.00

Deficiency Summary by Category

The following chart shows the total repair costs broken down by deficiency categories. Assessors assigned deficiencies to one of the following categories:



Deficiency Details by Priority

The deficiency detail notes listed below provide additional information on identified deficiencies found within the facility.

Priority 3 - Necessary (Years 2-5):

System: C1030 - Fittings



Location: Throughout building
Distress: Beyond Expected Life
Category: ADA Compliance
Priority: 3 - Necessary (Years 2-5)
Correction: Renew System
Qty: 75,286.00
Unit of Measure: S.F.
Estimate: \$246,788.00
Assessor Name: Jejuan Hall
Date Created: 02/14/2020

Notes:

The ADA signage, and storage shelving is from original construction and beyond the expected life for this application. The system is outdated and not current with the ADA standard, universal upgrades are recommended.

System: C3020901 - Carpet




Location: Throughout Building
Distress: Beyond Expected Life
Category: Deferred Maintenance
Priority: 3 - Necessary (Years 2-5)
Correction: Renew System
Qty: 5,000.00
Unit of Measure: S.F.
Estimate: \$41,250.00
Assessor Name: Hayden Collins
Date Created: 01/27/2020

Notes: The carpet floor finish is beyond its expected service life, worn and damaged, and is recommended for replacement.

School Assessment Report - 1996 Bldg 2010

System: D5010 - Electrical Service/Distribution



Location: Electrical Room
Distress: Beyond Expected Life
Category: Deferred Maintenance
Priority: 3 - Necessary (Years 2-5)
Correction: Renew System
Qty: 75,286.00

Unit of Measure: S.F.
Estimate: \$211,177.00
Assessor Name: Hayden Collins
Date Created: 09/27/2019

Notes: The electrical services and distribution system consist of an interior distribution system and branch panels with conduit and wiring to the lighting system. This system is beyond its expected life and universal upgrades are recommended.

Priority 4 - Recommended (Years 6-10):

System: D5090 - Other Electrical Systems

This deficiency has no image.

Location: Site
Distress: Missing
Category: Reliability
Priority: 4 - Recommended (Years 6-10)
Correction: Renew System
Qty: 75,286.00

Unit of Measure: S.F.
Estimate: \$31,470.00
Assessor Name: Hayden Collins
Date Created: 08/27/2013

Notes: No emergency generator, client standard required.

Executive Summary

The condition of a Campus is the accumulation of the condition evaluations of the component buildings and the site. Building condition is evaluated based on the functional systems and elements of a building and organized according to the **UNIFORMAT II Elemental Classification**. eCOMET uses parametric estimating methodology whereby historical costs for systems, components and equipment are collected by entities such as RSMeans and converted to unit costs, typically \$/SF, and used to approximate future construction costs or replacement values. The grouping of these systems and elements and applying a current replacement value to them develops a representative building cost model. Cost Models are developed for similar building types and functions. Systems and their elements are evaluated based on their current replacement values, life cycles, installation dates and next renewal dates. Systems and their elements that are within their useful lives are further evaluated to identify current deficient conditions that may have a significant impact on a system's or element's remaining service life, and to determine if they are beyond their predicted expected life. The system's or element's current replacement value is based on RS Means Commercial Cost Data.

Following are the cost model's system details for this facility. The **Current Replacement Value (CRV)** is the amount needed to replace the property of the same present scope. The **Repair Cost** (the sum of the cost to repair/replace the Deficiencies) represents the budgeted contractor-installed costs plus owner's soft costs for the repair, replacement or renewal for a component or system level deficiency. It excludes contributing costs for other components or systems that might also be associated with the corrective actions due to packaging of the work. **Facility Condition Index (FCI)** is an industry-standard measurement of facility condition calculated as the ratio of the costs to correct a facility's deficiencies (Condition Needs) to the facility's Current Replacement Value. It ranges from 0% (new) to 100% (very poor - beyond service life). The **Remaining Service Life Index (RSLI)** is calculated as the sum of a renewable system's **Remaining Service Life (RSL)** divided by the sum of a system's Replacement Value (both values exclude soft-cost to simplify calculation updates) expressed as a percentage ranging from 100% (new) to 0% (expired). The relationship between the key metrics FCI and RSLI is an important indicator, at either the facility, building, system, or component levels, of the condition trend and the imminent need for capital renewal. These indices exist in an inverse relationship wherein the FCI increases when systems reach their expected life-cycle age, whereas the RSLI decreases annually indicating the relative time remaining before reaching the life-cycle expiration age. For example, a facility or a system with a high RSLI and a low FCI indicates it is in the early portion of its useful life. However, a low RSLI indicates that expiration dates are approaching at which point the FCI would increase. The term **FCA Score** is the inverse of Total FCI and calculated as $100 - \text{Total FCI}$ (without the %) where 100 is best and 0 is worst condition.

Function:	
Gross Area (SF):	75,286
Year Built:	1996
Last Renovation:	
Replacement Value:	\$2,416,680
Repair Cost:	\$352,791.00
Total FCI:	14.60 %
Total RSLI:	28.54 %
FCA Score:	85.40



Description:


The narrative for this site is included in the Executive Summary Description at the front of this report.

Attributes: This asset has no attributes.


Dashboard Summary

Function:		Gross Area:	75,286
Year Built:	1996	Last Renovation:	
Repair Cost:	\$352,791	Replacement Value:	\$2,416,680
FCI:	14.60 %	RSLI%:	28.54 %


Deficiency By Category




Deficiency By Priority



Deficiency By System



10 Year Investment Forecast



Condition Summary

The Table below shows the RSLI and FCI for each major building system shown at the UNIFORMAT II classification Level 2. Note that Systems with lower FCIs require less investment than systems with higher FCIs.

UNIFORMAT Classification	RSLI %	FCI %	Current Repair Cost
G20 - Site Improvements	29.48 %	0.00 %	\$0.00
G30 - Site Mechanical Utilities	54.00 %	0.00 %	\$0.00
G40 - Site Electrical Utilities	8.74 %	68.81 %	\$352,791.00
Totals:	28.54 %	14.60 %	\$352,791.00

Photo Album

The photo album consists of the various cardinal compass directions of the building..



Condition Detail

This section of the report contains results of the Facility Condition Assessment. The building is separated into system components based on UNIFORMAT II. The columns in the System Listing table represent the following:

1. System Code: A code that identifies the system.
2. System Description: A brief description of a system present in the building.
3. Unit Price \$: The unit price of the system.
4. UoM: The unit of measure of the system.
5. Qty: The quantity for the system
6. Life: Building Owners and Managers Association (BOMA) recommended system design life.
7. Year Installed: The date of system installation.
8. Calc Next Renewal Year: The date of system expiration based on the life, NR stands for non renewable.
9. Next Renewal Year: The suggested system expiration date by the assessor based on visual inspection.
10. RSLI: The Remaining Service Life Index of the system.
11. FCI: The Facility Condition Index of the system.
12. RSL: Remaining Service Life in years.
13. eCR: eCOMET Condition Rating (not used in this assessment)
14. Deficiency \$: The financial investment to repair/replace system to address deficiency.
15. Replacement Value \$: The replacement cost of the system as new construction.

System Listing

The System Listing table below lists each of the systems organized by their UNIFORMAT II classification. The assessment team was tasked with recording the most recent replacement year of each system, determining the remaining service life based on the theoretical life, and evaluating the condition to confirm the forecast next replacement year. The system listing is the basis for all data contained in the Building Assessment Report.

System Code	System Description	Unit Price \$	UoM	Qty	Life	Year Installed	Calc Next Renewal Year	Next Renewal Year	RSLI%	FCI%	RSL	eCR	Deficiency \$	Replacement Value \$
G2010	Roadways	\$2.37	S.F.	75,286	35	1996	2031		34.29 %	0.00 %	12			\$178,428
G2020	Parking Lots	\$8.00	S.F.	75,286	35	1996	2031		34.29 %	0.00 %	12			\$602,288
G2030	Pedestrian Paving	\$2.33	S.F.	75,286	35	1996	2031		34.29 %	0.00 %	12			\$175,416
G2040105	Fence & Guardrails	\$1.15	S.F.	75,286	30	1996	2026		23.33 %	0.00 %	7			\$86,579
G2040950	Covered Walkways	\$1.44	S.F.	75,286	25	1996	2021		8.00 %	0.00 %	2			\$108,412
G2040950	Playing Field	\$4.28	S.F.	75,286	20	1996	2016	2025	30.00 %	0.00 %	6			\$322,224
G2050	Landscaping	\$1.18	S.F.	75,286	25	1996	2021		8.00 %	0.00 %	2			\$88,837
G3010	Water Supply	\$1.09	S.F.	75,286	50	1996	2046		54.00 %	0.00 %	27			\$82,062
G3020	Sanitary Sewer	\$2.20	S.F.	75,286	50	1996	2046		54.00 %	0.00 %	27			\$165,629
G3030	Storm Sewer	\$1.25	S.F.	75,286	50	1996	2046		54.00 %	0.00 %	27			\$94,108
G4010	Electrical Distribution	\$2.55	S.F.	75,286	30	1996	2026		23.33 %	0.00 %	7			\$191,979
G4020	Site Lighting	\$2.98	S.F.	75,286	30	1996	2026	2013	0.00 %	110.00 %	-6		\$246,788.00	\$224,352
G4030	Site Communication and Security	\$1.28	S.F.	75,286	30	1996	2026	2013	0.00 %	110.00 %	-6		\$106,003.00	\$96,366
Total									28.54 %	14.60 %			\$352,791.00	\$2,416,680

System Notes

The facility description in the executive summary contains an overview of each system. The system notes listed below provide additional information on select systems found within the facility.

System: G2010 - Roadways



Note:

System: G2020 - Parking Lots



Note:

System: G2030 - Pedestrian Paving



Note:

School Assessment Report - Site

System: G2040105 - Fence & Guardrails



Note:

System: G2040950 - Covered Walkways



Note:

System: G2040950 - Playing Field



Note:

School Assessment Report - Site

System: G2050 - Landscaping



Note:

System: G3010 - Water Supply



Note:

System: G3020 - Sanitary Sewer



Note:

School Assessment Report - Site

System: G3030 - Storm Sewer




Note:

System: G4010 - Electrical Distribution



Note:


System: G4020 - Site Lighting



Note:

School Assessment Report - Site

System: G4030 - Site Communication and Security



Note:

Renewal Schedule

eCOMET forecasts future Capital Renewal projects for expiring systems based on the Calculated Next Renewal year found in the System Listing table. There is a 3% yearly inflation factor applied to the system costs expiring in the future. The table below reflects Capital Renewal projects over the next 10 years. Note: Blank cells (or \$0) indicate no systems are scheduled for renewal in that year.


Inflation Rate: 3%

System	Current Deficiencies	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	Total
Total:	\$352,791	\$0	\$230,188	\$0	\$0	\$0	\$423,227	\$376,851	\$0	\$0	\$0	\$1,383,056
G - Building Sitework	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
G20 - Site Improvements	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
G2010 - Roadways	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
G2020 - Parking Lots	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
G2030 - Pedestrian Paving	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
G2040 - Site Development	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
G2040105 - Fence & Guardrails	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$117,129	\$0	\$0	\$0	\$117,129
G2040950 - Covered Walkways	\$0	\$0	\$126,516	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$126,516
G2040950 - Playing Field	\$0	\$0	\$0	\$0	\$0	\$0	\$423,227	\$0	\$0	\$0	\$0	\$423,227
G2050 - Landscaping	\$0	\$0	\$103,672	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$103,672
G30 - Site Mechanical Utilities	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
G3010 - Water Supply	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
G3020 - Sanitary Sewer	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
G3030 - Storm Sewer	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
G40 - Site Electrical Utilities	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
G4010 - Electrical Distribution	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$259,721	\$0	\$0	\$0	\$259,721
G4020 - Site Lighting	\$246,788	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$246,788
G4030 - Site Communication and Security	\$106,003	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$106,003

* Indicates non-renewable system

Forecasted Capital Renewal Requirement

The following chart shows the current building deficiencies and forecasted capital renewal (sustainment) requirements over the next ten years.




Condition Index Forecast by Investment Scenario

The chart below illustrates the effect of various investment levels on the building FCI for the next 10 years. The levels of investment shown below include:

- Current FCI: a variable investment amount based on renewing expired systems to maintain the current FCI for the building
- 2% Investment: an annual investment of 2% of the replacement value of the building, escalated for inflation
- 4% Investment: an annual investment of 4% of the replacement value of the building, escalated for inflation


Facility Investment vs. FCI Forecast



Year	Investment Amount Current FCI - 14.6%	2% Investment		4% Investment	
		Amount	FCI	Amount	FCI
2020	\$0	\$49,784.00	12.60 %	\$99,567.00	10.60 %
2021	\$230,188	\$51,277.00	19.58 %	\$102,554.00	15.58 %
2022	\$0	\$52,815.00	17.58 %	\$105,631.00	11.58 %
2023	\$0	\$54,400.00	15.58 %	\$108,800.00	7.58 %
2024	\$0	\$56,032.00	13.58 %	\$112,064.00	3.58 %
2025	\$423,227	\$57,713.00	26.24 %	\$115,426.00	14.24 %
2026	\$376,851	\$59,444.00	36.92 %	\$118,888.00	22.92 %
2027	\$0	\$61,228.00	34.92 %	\$122,455.00	18.92 %
2028	\$0	\$63,064.00	32.92 %	\$126,129.00	14.92 %
2029	\$0	\$64,956.00	30.92 %	\$129,913.00	10.92 %
Total:	\$1,030,265	\$570,713.00		\$1,141,427.00	


Deficiency Summary by System

Current deficiencies included assemblies that have reached or exceeded their design life or components of the assemblies that are in need of repair. Assemblies that have reached their design life are identified as current deficiencies and assigned the distress 'Beyond Useful Life'. The following chart lists all current deficiencies associated with this facility.



Deficiency Summary by Priority

The following chart shows the total repair costs broken down by priority. Assessors assigned deficiencies within eCOMET to one of the following priority categories:



Budget Estimate Total: \$352,791.00


Deficiency By Priority Investment Table

The table below shows the current investment cost grouped by deficiency priority and building system.

System Code	System Description	1 - Critical Immediate Need	2 - Trending Critical (Year 1)	3 - Necessary (Years 2-5)	4 - Recommended (Years 6-10)	5 - Grandfathered Project triggered	Total
G4020	Site Lighting	\$0.00	\$0.00	\$246,788.00	\$0.00	\$0.00	\$246,788.00
G4030	Site Communication and Security	\$0.00	\$0.00	\$106,003.00	\$0.00	\$0.00	\$106,003.00
	Total:	\$0.00	\$0.00	\$352,791.00	\$0.00	\$0.00	\$352,791.00

Deficiency Summary by Category

The following chart shows the total repair costs broken down by deficiency categories. Assessors assigned deficiencies to one of the following categories:



Deficiency Details by Priority

The deficiency detail notes listed below provide additional information on identified deficiencies found within the facility.

Priority 3 - Necessary (Years 2-5):


System: G4020 - Site Lighting



Location: Site
Distress: Beyond Expected Life
Category: Deferred Maintenance
Priority: 3 - Necessary (Years 2-5)
Correction: Renew System
Qty: 75,286.00
Unit of Measure: S.F.
Estimate: \$246,788.00
Assessor Name: Jejuan Hall
Date Created: 02/22/2020

Notes: Principal reports that site lighting overall is inadequate and cause of security concern.

System: G4030 - Site Communication and Security



Location: Site
Distress: Beyond Expected Life
Category: Deferred Maintenance
Priority: 3 - Necessary (Years 2-5)
Correction: Renew System
Qty: 75,286.00
Unit of Measure: S.F.
Estimate: \$106,003.00
Assessor Name: Jejuan Hall
Date Created: 02/22/2020

Notes: Principal reported that on several occasions site Security System has failed resulting in property loss and raising anxiety level of students and staff.

Glossary

Abandoned	A facility owned by the city that is not occupied and not maintained. See Vacant.
Additional Cost	Total project cost is composed of hard and soft costs. Additional costs or soft expenses are costs that are necessary to accomplish the corrective work but are not directly attributable to the deficient systems direct construction cost, which are often referred to as hard cost. The components included in the soft costs vary by owner but usually include architect and contractor fees, contingencies and other owner-incurred costs necessary to fully develop and build a facility. These soft cost factors can be adjusted anytime within the eCOMET database at the owner's discretion.
Assessment	Visual survey of a facility to determine its condition. It involves looking at the age of systems, reviewing information from local sources and visual evidence of potential problems to assign a condition rating. It does not include destructive testing of materials or testing of systems or equipment for functionality.
ASTM	ASTM International (ASTM): Originally known as the American Society for Testing and Materials, ASTM is an international standards organization that develops and publishes voluntary consensus technical standards for a wide range of materials, products, systems, and services.
BOMA	Building Owners Managers of America (BOMA): National organization of public and private facility owners focused on building management tools and maintenance techniques. eCOMET® reference: Building and component system effective economic life expectancies.
Building	A fully enclosed and roofed structure that can be traversed internally without exiting to the exterior.
Building Addition	An area, space or component of a building added to a building after the original building's year built date. NOTE: As a convention in the database, "Main" was used to designate the original building. Additions built prior to 1987 (30 years) were included in the main building area calculations to reflect their predicted system depreciation characteristics and remaining service life.
Building Systems	eCOMET® uses UNIFORMAT II to organize building data. UNIFORMAT II was originally developed by the federal General Services Administration to delineate building costs by systems rather than by material. UNIFORMAT II was formalized by an NIST standard, NISTIR 6389 in 1999. It has been further quantified and updated by ASTM standard 2005, E1557-05. The Construction Specifications Institute, CSI, has taken over the standard as part of their MasterFormat / MasterSpec system.
Calculated Next Renewal	The year a system or building element would be expected to expire based solely on the date it was installed and the expected useful lifetime for that kind of system.
Capital Renewal	Capital renewal refers to the cyclical replacement of building systems or elements as they become obsolete or beyond their useful life. It is not normally included in an annual operating/maintenance budget. See calculated next renewal and next renewal.
City Cost Index (CCI)	RS Means provides building system, equipment, and construction costs at a national level. The City Cost Index (also provided by RS Means) localizes those costs to a geographic region of the United States. In eCOMET®, each building or site is assigned a City Cost Index, which adjusts all of the associated costs for systems, deficiencies and inventory to the local value.
Condition	Condition refers to the state of physical fitness or readiness of a facility system or system element for its intended use.
Condition Budget	The Condition Budget, also known as Condition Needs, represents the budgeted contractor installed costs plus owner's soft costs for the repair, replacement or renewal for a component or system level deficiency. It excludes contributing costs for other components or systems that might also be associated with the corrective actions due to packaging the work.

School Assessment Report - Cleveland Avenue Elementary School

Condition Index (CI) %	The Condition Index (CI) also known as the Remaining Service Life Index (RSLI) is calculated as the sum of a renewable system's Remaining Service Life (RSL) Value divided by the sum of a system's Replacement Value (both values exclude soft cost to simplify calculation updates) expressed as a percentage ranging from 100.00% (new) to 0.00% (expired - no remaining life).
Correction	Correction refers to an assessor's recommended deficiency repair or replacement action. For any system or element deficiency, there can be multiple and alternative solutions for its repair or replacement. A Correction is user defined and tied to a UNIFORMAT II element, or system it is intended to address. It excludes other peripheral costs that may also be included in the packaging of repair, replacement or renewal improvements that may also be triggered by the deficiency correction.
Cost Model	A cost model is a list of facility systems which could represent the installed systems a given facility. Included in the cost model are standard unit cost estimates, gross areas, life cycles and installed dates. Also represented is the repair cost for deficient systems, replacement values. See eCOMET® cost models.
Criteria	Criteria refer to the set of requirements, guidelines or standards that are assessed and rated to develop a score.
Current Period	The Current Period is the current year plus a user defined number of forward years.
Current Replacement Value (CRV)	The Current Replacement Value (CRV) of a facility, building or system represents the hypothetical cost of rebuilding or replacing an existing facility under today's codes and construction standards, using its current configuration. It is calculated by multiplying the gross area of the facility by a square foot cost developed in that facility's cost model. Replacement cost includes construction costs and owner's additional or soft costs for fees, permits and other expenses to reflect a total project cost.
Deferred Maintenance	Deferred maintenance is condition work deferred on a planned or unplanned basis to a future budget cycle or postponed until funds are available.
Deficiency	A deficiency is a repair item that is damaged, missing, inadequate or insufficient for an intended purpose.
Deficiency Category	Category refers to the type or class of a user defined deficiency grouping with shared or similar characteristics. Category descriptions include, but are not limited to: Accessibility Code Compliance, Appearance, Building Code Compliance, Deferred Maintenance, Energy, Environmental, Life Safety Code Compliance, and Safety.
Deficiency Priority	Priority refers to a deficiency's urgency for repair as determined by the assessment team. Five typical industry priority settings were used for the assessment: Priority 1 – Currently Critical; Priority 2 – Potentially Critical; Priority 3 – Necessary/Not Yet Critical; Priority 4 – Recommended.
Distress	Distress refers to a user-defined root cause of a deficiency. Distress descriptions are: Beyond Service Life, Damaged, Inadequate, Needs Remediation, and Missing.
eCOMET®	Energy and Condition Management Estimation Technology (eCOMET®) is Parsons proprietary facility asset management software developed to provide facility managers with a state of the art, web-based tool to develop and maintain a comprehensive database of FCA data and information used for facility asset management, maintenance and repair, and capital renewal planning. eCOMET® is used by Parsons and its clients as the primary tool for collecting FCA data, preparing cost estimates, generating individual facility reports and cost estimates, and developing the overall capital renewal program.
eCOMET® Cost Models	eCOMET cost models are derived from RS Means Square Foot Cost Data cost models and these models are used to develop the current replacement value (CRV) and assign life cycle costs to the various systems within a building. Cost models are assigned current costs-per-square-foot to establish replacement values. The Cost models are designed to represent a client specific facility that meets local standards cost trends.

School Assessment Report - Cleveland Avenue Elementary School

Element	Elements are the major components that comprise building systems as defined by UNIFORMAT II.
Expected Life	Also referred to as Useful Life. See Useful Life definition.
Facility	A facility refers to site(s) building(s) or building addition(s) or combinations thereof that provide a particular service.
Facility Attributes	Customizable eCOMET fields to identify attributes specific to a facility. These fields are part of the eCOMET database set-up with the owner.
Facility Condition Assessment (FCA)	A facility condition assessment (FCA) is a visual inspection of buildings and grounds at a facility to identify and estimate current and future needed repairs or replacements of major systems for planning and budgeting purposes. It is typically performed for organizations that are tasked with the day to day maintenance, operation, and capital renewal (replacement) of building systems and components of a large inventory of facilities. The primary goal of an FCA is to objectively and quantifiably identify, inspect, and prioritize the repair and replacement needs of the building and ground systems (e.g., roofs, windows, doors, floor finishes, plumbing fixtures, parking lot, and sidewalks) within facilities that have either failed or have surpassed their service life, and to identify and forecast future capital replacement needs for systems that have not yet failed, but planned replacement of those systems is needed to ensure that the facilities will continue to meet the mission of the organization.
Facility Condition Index (FCI%)	FCI is an industry-standard measurement of a facility's condition that is the ratio of the cost to correct a facility's deficiencies to the Current Replacement Value of the facilities. The higher the FCI the poorer the condition of a facility. After an FCI is established for all buildings within a portfolio a building's condition can be ranked relative to other buildings. The FCI may also represent the condition of a portfolio based on the cumulative FCIs of the portfolio's facilities.
Forecast Period	The Forecast Period refers to a user defined number of years forward of the Current Period.
Gen (Generate)	The Cost Model has a Gen box for each system line item. By checking the box, eCOMET will generate life cycle deficiencies based on the Year Installed and the Life for that system. Systems that typically do not re-generate (foundations, floor construction, roof construction, basement walls, etc.) would not have the Gen box checked as those systems would not re-generate at the end of a life cycle. In those instances, it would be more practical and cost effective to demolish the entire facility than re-new those systems.
Gross Square Feet (GSF)	The size of the enclosed floor space of a building in square feet measured to the outside face of the enclosing wall.
Life Cycle	Life cycle refers to the period of time that a building or site system or element can be expected to adequately serve its intended function. Parsons assigns expected life cycles to all building systems based on Building Operators and Managers of America (BOMA) recommended life cycles, manufacturers suggested life, and RS Means cost data, and client-provided historical data. BOMA standards are a nationally recognized source of life cycle data for various components and/or systems associated with facilities. RS Means is a national company specializing in construction estimating and costs.
Next Renewal	Next Renewal refers to a manually-adjusted expected useful life of a system or element based on on-site inspection either by reducing or extending the Calculated Next Renewal to more accurately reflect current conditions.
Order of Magnitude	Order of Magnitude refers to a rough approximation made with a degree of knowledge and confidence that the budgeted, projected or estimated cost falls within a reasonable range of cost values.
Remaining Service Life (RSL)	RSL is the number of years service remaining for a system or equipment item. It is automatically calculated based on the difference between the current year and the 'Calculated Next Renewal' date or the 'Next Renewal' date whichever one is the later date.

School Assessment Report - Cleveland Avenue Elementary School

Remaining Service Life Index (RSLI)	The Remaining Service Life Index (RSLI), also known as the Condition Index (CI), is calculated as the sum of a renewable system's or component's Remaining Service Life (RSL) Value divided by the sum of a system's or component's Replacement Value (both values exclude softcost to simplify calculation updates) expressed as a percentage ranging from 100.00% (new) to 0.00% (expired - no remaining service life).
Remaining Service Life Value	Remaining Service Life Value, also known as the RSL Weight, is a calculated value used to determine the RSLI and is equal to the system Value (Unit Cost * Qty) * RSL (not displayed).
Renewal Factors	Renewal factors represent the difference in cost of renovating or replacing an existing system, rather than new construction of a building system. For example, installing a new built-up roof on an existing building would include removing and disposing of the old roof, a cost not associated with new construction. Using a renewal premium to account for demolition and other difficulty costs, Parsons typically assigns a renewal factor of 110%.
Renewal Schedule	A timeline that provides the items that need repair the year in which the repair is needed and the estimated price of the renewal.
Repair Cost	Repair cost is the sum of all the deficiencies associated with a building or multiple buildings/facilities. It will include any applied soft costs or City Cost Indexes.
Replacement Value	See Current Replacement Value.
Site	A facility's grounds and its utilities, roadways, landscaping, fencing and other typical land improvements needed to support a facility.
Soft Costs	Soft Costs are a construction industry term that refers to expense items that are not considered direct construction costs. Soft costs are user-defined and include architectural, engineering, management, testing, and mitigation fees, and other owner pre- and post-construction expenses.
Sustainability	Sustainability refers to the collection of policies and strategies that meet society's present needs without compromising the ability of future generations to meet their own needs.
System	System refers to building and related site work elements as described by ASTM Uniformat II Classification for Building Elements (E1557-97) a format for classifying major facility elements common to most buildings. Elements usually perform a given function regardless of the design specification construction method or materials used. See also Uniformat II.
System Generated Deficiency	eCOMET automatically generates system deficiencies based on system life cycles using the systems installation dates as the base year. By adjusting the Next Renewal date ahead or behind the predicted or stated life cycle date, a system cost will come due earlier or later than the originally installed life cycle date. This utility accounts for good maintenance conditions and a longer life, or early expiration of a system life due to any number of adverse factors such as poor installation, acts of god, material defects, poor design applications and other factors that may shorten the life of a material or system. It is important to mention that the condition of the systems is not necessarily a reflection of maintenance practices, but a combination of system usage and age.
UNIFORMAT	ASTM UNIFORMAT II, Classification for Building Elements (E1557-97), a publication of the Construction Specification Institute (CSI), is a format used to classify major facility components common to most buildings. The format is based on functional elements or parts of a facility characterized by their functions without regard to the materials and methods used to accomplish them. These elements are often referred to as systems or assemblies.
Unit Price	The Unit Price (Raw) x the Additional Cost Template percentage.
Unit Price (Raw)	The actual \$/sq. ft. cost being used for the building and systems. It will include adjustments for the City Cost Index applied to the facility.

School Assessment Report - Cleveland Avenue Elementary School

Useful Life	Also known as Expected Life, Useful Life refers to the intrinsic period of time a system or element is expected to perform as intended. Useful life is generally provided by manufacturers of materials, systems and elements through their literature, testing and experience. Useful Lives in the database are derived from the Building Owners and Managers (BOMA) organization's guidelines, RSMeans cost data, and from client- defined historical experience.
Vacant	Vacant refers to a facility that is not occupied but is a maintained facility. See Abandoned.
Year Built	The year that a building or addition was originally built based on substantial completion or occupancy.
Year Installed	The year a system or element was built or the most recent major renovation date where a minimum of 70% of the system's Current Replacement Value (CRV) was replaced.



Suitability Report - Full

Project #: 12382	County: Atlanta Public Schools	Site #: 4056
Project: APS Assessments 2019	Region: 761	Site: Cleveland Avenue ES
Grade Config: PK-5	Site Type: Elementary	Site Size: 16.00

Suitability	Rating	Score	Possible Score	Percent Score
Suitability - ES				
Learning Environment				
Learning Style Variety	Excel	5.00	5.00	100.00
Interior Environment	Excel	2.00	2.00	100.00
Exterior Environment	Excel	1.50	1.50	100.00
General Classrooms				
Environment	Good	3.72	4.65	80.00
Size	Good	9.30	11.63	80.00
Location	Good	2.79	3.49	80.00
Storage/Fixed Equip	Excel	3.49	3.49	100.00
Kindergarten				
Environment	Good	0.33	0.42	80.00
Size	Excel	1.04	1.04	100.00
Location	Excel	0.31	0.31	100.00
Storage/Fixed Equip	Excel	0.31	0.31	100.00
ECE				
Environment	Excel	0.50	0.50	100.00
Size	Excel	1.25	1.25	100.00
Location	Fair	0.24	0.37	65.00
Storage/Fixed Equip	Good	0.30	0.37	80.00
Self-Contained Special Ed				
Environment	Good	0.38	0.48	80.00
Size	Excel	1.20	1.20	100.00
Location	Good	0.29	0.36	80.00
Storage/Fixed Equip	Fair	0.23	0.36	65.00
Instructional Resource Rooms				
Environment	Good	0.58	0.72	80.00
Size	Excel	1.80	1.80	100.00
Location	Good	0.43	0.54	80.00
Storage/Fixed Equip	Good	0.43	0.54	80.00
Science				
Environment	Good	0.32	0.40	80.00
Size	Good	0.80	1.00	80.00
Location	Good	0.24	0.30	80.00
Storage/Fixed Equip	Poor	0.15	0.30	50.00
Music				
Environment	Good	0.59	0.74	80.00

Project #: 12382

County: Atlanta Public Schools

Site #: 4056

Project: APS Assessments 2019

Region: 761

Site: Cleveland Avenue ES

Grade Config: PK-5

Site Type: Elementary

Site Size: 16.00

Suitability	Rating	Score	Possible Score	Percent Score
Size	Excel	1.85	1.85	100.00
Location	Excel	0.56	0.56	100.00
Storage/Fixed Equip	Excel	0.56	0.56	100.00
Art				
Environment	Good	0.37	0.47	80.00
Size	Excel	1.17	1.17	100.00
Location	Excel	0.35	0.35	100.00
Storage/Fixed Equip	Poor	0.18	0.35	50.00
Maker Space				
Environment	Good	0.28	0.35	80.00
Size	Fair	0.57	0.88	65.00
Location	Good	0.21	0.26	80.00
Storage/Fixed Equip	Good	0.21	0.26	80.00
Computer Labs				
Environment	Excel	0.34	0.34	100.00
Size	Unsat	0.00	0.85	0.00
Location	Good	0.20	0.26	80.00
Storage/Fixed Equip	Good	0.20	0.26	80.00
P.E.				
Environment	Excel	1.92	1.92	100.00
Size	Good	3.84	4.80	80.00
Location	Excel	1.44	1.44	100.00
Storage/Fixed Equip	Good	1.15	1.44	80.00
Performing Arts				
Environment	Excel	0.60	0.60	100.00
Size	Good	1.21	1.51	80.00
Location	Excel	0.45	0.45	100.00
Storage/Fixed Equip	Good	0.36	0.45	80.00
Media Center				
Environment	Excel	0.97	0.97	100.00
Size	Excel	2.44	2.44	100.00
Location	Excel	0.73	0.73	100.00
Storage/Fixed Equip	Excel	0.73	0.73	100.00
Restrooms (Student)	Fair	0.58	0.89	65.00
Administration	Good	2.05	2.56	80.00
Counseling	Good	0.23	0.29	80.00
Clinic	Good	0.47	0.58	80.00
Staff WkRm/Toilets	Good	1.01	1.27	80.00
Cafeteria	Excel	5.00	5.00	100.00
Food Service and Prep	Excel	6.20	6.20	100.00
Custodial and Maintenance	Good	0.40	0.50	80.00
Outside				
Vehicular Traffic	Good	1.60	2.00	80.00
Pedestrian Traffic	Fair	0.63	0.97	65.00
Parking	Fair	0.53	0.81	65.00
Play Areas	Fair	1.52	2.34	65.00

Project #: 12382

County: Atlanta Public Schools

Site #: 4056

Project: APS Assessments 2019

Region: 761

Site: Cleveland Avenue ES

Grade Config: PK-5

Site Type: Elementary

Site Size: 16.00

Suitability	Rating	Score	Possible Score	Percent Score
Safety and Security				
Fencing	Poor	0.38	0.75	50.00
Signage & Way Finding	Poor	0.50	1.00	50.00
Ease of Supervision	Fair	1.95	3.00	65.00
Controlled Entrances	Good	0.40	0.50	80.00
Total For Site:		85.90	100.00	85.90

Comments

Suitability - ES

Cleveland Avenue school is a neighborhood elementary school serving students in grades K-5. The single story school was built in 1996. The school is STEM certified and supports autism and special education services. The school provides free breakfast and lunch to all the of the students.

Suitability - ES->General Classrooms-->Environment

The artificial and natural light is adequate but difficult to control.

Suitability - ES->ECE-->Location

The room is not located to provide access to a separated fenced, outdoor play area designed for ECE.

Suitability - ES->ECE-->Storage/Fixed Equip

There is no access to a washer and dryer area.

Suitability - ES->Self-Contained Special Ed-->Environment

The artificial and natural light is adequate but difficult to control.

Suitability - ES->Self-Contained Special Ed-->Location

The door opens into the auxiliary halls and has windows for viewing traffic.

Suitability - ES->Self-Contained Special Ed-->Storage/Fixed Equip

There is no shower or washer/dryer available within the space.

Suitability - ES->Science-->Storage/Fixed Equip

There is minimal secure casework available for storage and there is not a separate room for storage.

Suitability - ES->Art-->Environment

There is ample artificial and natural light available but there is no way to control the light level.

Suitability - ES->Art-->Storage/Fixed Equip

There is no ventilation for the kiln.

Suitability - ES->Maker Space-->Size

The space is 68% of the identified standard size.

Suitability - ES->Maker Space-->Storage/Fixed Equip

There is space to accommodate storage but there is not an adequate amount of fixed storage available.

Suitability - ES->Computer Labs-->Size

The computer lab is 44% of the size standards.

Suitability - ES->P.E.-->Storage/Fixed Equip

The flooring is not rubberized.

Suitability - ES->Restrooms (Student)

There are no urinal partitions in place.

Project #: 12382

County: Atlanta Public Schools

Site #: 4056

Project: APS Assessments 2019

Region: 761

Site: Cleveland Avenue ES

Grade Config: PK-5

Site Type: Elementary

Site Size: 16.00

Suitability	Rating	Score	Possible Score	Percent Score
Suitability - ES->Administration				
The mailboxes are not in a secure location away from the general public.				
Suitability - ES->Clinic				
The intended nursing office space is not currently used which does provide the adequate space and location for the office, beds and access to a restroom. The current space does not have enough space for two beds, does not have lockable storage or immediate access for a restroom.				
Suitability - ES->Outside-->Pedestrian Traffic				
Pedestrian traffic flow conflicts with vehicle traffic and requires staff to assist with students crossing vehicle traffic.				
Suitability - ES->Outside-->Parking				
There is no signage to identify visitor parking.				
Suitability - ES->Outside-->Play Areas				
There is no ADA access or equipment on the playground.				
Suitability - ES->Safety and Security-->Fencing				
The site is not appropriately fenced to secure the students from the public.				
Suitability - ES->Safety and Security-->Signage & Way Finding				
There is not adequate signage to identify the main entrance and it is lacking the safety/security signage. The signage that marks the school at the main entrance deters visibility from oncoming traffic.				
Suitability - ES->Safety and Security-->Ease of Supervision				
There is only one security camera on the building exterior and the expanse of space on the playfield into the vegetation inhibits the line of sight.				